



TYPICAL WATER METER INSTALLATION CONFIGURATIONS (YOURS MAY VARY)

TYPE 1 RESIDENTIAL




MINIMUM OF FIVE DIAMETERS OF STRAIGHT PIPE REQUIRED BEFORE METER AND TWO DIAMETERS AFTER

TYPE 2 RESIDENTIAL OR COMMERCIAL WITH RPZ



MINIMUM OF FIVE DIAMETERS OF STRAIGHT PIPE REQUIRED BEFORE METER AND TWO DIAMETERS AFTER

TYPE 3 RESIDENTIAL OR COMMERCIAL WITH RPZ AND IRRIGATION



TYPE 4 3 - INCH OR LARGER RESIDENTIAL OR COMMERCIAL WITH BYPASS, RPZ AND IRRIGATION.

